Review Location: Reviewer: Date of Review:

NR.	ITEM	Y	\mathbf{N}	N/A	FINDING*	RECOMMENDATIONS	DISA/NIST MINIMUM SECURITY STANDARD FOR RESTRICTED AREAS	BEST PRACTICE
	1.0 Documentation (InfoSec Docs)							
1.1	Security Policy						X	X
1.2	Incidence Response Plan						X	X X
1.3	Disaster Recovery Plan (DRP) including natural disasters (flood, hurricane, earthquake, fire, etc)						X	X
1.4	Access Control Documentation						X	X
1.5	Backup Plan						X	X
1.6	Key control is logged, maintained, and reviewed						X	X
	2.0 Safety							
2.1	Emergency exits are present and clearly marked						X	X
2.2	Emergency lights with backup power						X	X
2.3	Safety inspection sticker is current						X	X

NR.	ITEM	Y	\mathbf{N}	N/A	FINDING*	RECOMMENDATIONS	DISA/NIST MINIMUM SECURITY STANDARD FOR RESTRICTED AREAS	BEST PRACTICE
	3.0 Physical Access							
3.1	Picture identification is present and visible						X	X
3.2	Badge is present and visible						X	X
3.3	Visitors Sign In/Out Log						X	X
3.4	Badge control policies in place						X	X
3.5	Smart Card logs Badge logs are maintained and audited						X	X
3.6	Access card or token swiped or presented at automated reader for building/secure area entry or presentation of access card to security personnel required for building/secure area entry						X	X
3.7	Key control is logged, maintained, and reviewed						X	X

NR.	ITEM	Y	N	N/A	FINDING*	RECOMMENDATIONS	DISA/NIST MINIMUM SECURITY STANDARD FOR RESTRICTED AREAS	BEST PRACTICE
3.8	Authorized personnel access list is displayed inside the Data Center (DC) door						X	X
3.9	Data backup tapes are securely stored on-site until moved to off-site facility						X	X
3.10	Data backup tapes are securely stored off-site						X	X
3.11	Deposits and withdrawals of tapes and other storage media from the data backup library is authorized and logged						X	X
3.12	Unattended terminals are password protected						X	X
3.13	Password protected screen saver is set to turn on automatically after 15 minutes of inactivity						X	X

NR.	ITEM	Y	\mathbf{N}	N/A	FINDING*	RECOMMENDATIONS	DISA/NIST MINIMUM SECURITY STANDARD FOR RESTRICTED AREAS	BEST PRACTICE
	4.0 Facilities							
4.1	Windows protected by Intrusion Detection Systems (IDS) if less than 18 feet from ground or roof level						X	X
4.2	Openings over 96 square inches covered by material the same as the wall or by iron bars, or 18 gauge wire mesh						X	X
4.3	Individual personnel must have access to restricted areas (must not allow piggybacking or entry to unauthorized individuals)						X	X
4.4	Entrance doors must be constructed of solid wood, metal, or metal clad						X	X

NR.	ITEM	Y	N	N/A	FINDING*	RECOMMENDATIONS	DISA/NIST MINIMUM SECURITY STANDARD FOR RESTRICTED AREAS	BEST PRACTICE
4.5	Emergency doors						X	X
	will be void of all							
	devices on the outside thereby							
	allowing exit but no							
	entry							
4.6	Emergency doors						X	X
	will be equipped with							
	emergency bar							
	openers on the inside with a deadbolt throw							
	of at least ½ inch							
4.7	Doors have hinges on						X	X
1.,	the inside. If door							11
	hinges are on the							
	outside, the hinges							
	must be peened,							
	welded or equipped							
	with setscrew							
1	fastener						1	

NR.	ITEM	Y	N	N/A	FINDING*	RECOMMENDATIONS	DISA/NIST MINIMUM SECURITY STANDARD FOR RESTRICTED AREAS	BEST PRACTICE
4.8	Simple magnetic alarm switch should be placed on the protected side of doors, windows, or other moveable openings greater than 96 square inches to protect against movement						X	X
4.9	Walls, solid and contained from true floor to next floor or roof						X	X
4.10	True Floor to ceiling walls constructed of a material that would provide detections of surreptitious entry						X	X
4.11	Building and secure areas are protected with true ceilings and true floors						X	Х
4.12	Roving guard						X	X

NR.	ITEM	Y	\mathbf{N}	N/A	FINDING*	RECOMMENDATIONS	DISA/NIST MINIMUM SECURITY STANDARD FOR RESTRICTED AREAS	BEST PRACTICE
4.13	Security lighting for all exterior doors						X	X
	5.0 Environmental							
5.1	Appropriate fire extinguishers (levels A, B, C) are present with current inspection information						X	X
5.2	Heat Ventilation Air Conditioning (HVAC) is present and working						X	X
5.3	Water sprinklers are present and in working condition						X	X
5.4	Heat and smoke sensors are present and in working condition						X	X
5.5	Uninterrupted Power Supply (UPS) is present and in working condition						X	X
5.6	24 hour temperature monitor/alarm is present and working						X	X
	6.0 Human Threat							

NR.	ITEM	Y	N	N/A	FINDING*	RECOMMENDATIONS	DISA/NIST MINIMUM SECURITY STANDARD FOR RESTRICTED AREAS	BEST PRACTICE
6.1	Internal threat policies/procedures in place						X	X
6.2	External threat policies/procedures in place						X	X
6.3	Sabotage policies/procedures in place						X	X
6.4	Power Outage policies/procedures in place						X	X
	7.0 Mobil Computing Devices							
7.1	Unattended portable and wireless devices are secured and locked						X	Х
7.2	Unattended removable media containing sensitive information is secured and locked						X	X

NR.	ITEM	Y	\mathbf{N}	N/A	FINDING*	RECOMMENDATIONS	DISA/NIST MINIMUM SECURITY STANDARD FOR RESTRICTED AREAS	BEST PRACTICE
0.1	8.0 Sensitive Data							
8.1	Sensitive data should be erased from whiteboards, removed from unsecured areas, and be properly disposed of						X	X
	9.0 Hard Copy Output Access							
9.1	Hard copy sensitive information that is no longer required is shredded or destroyed						X	X
9.2	All sensitive hard copy output is immediately picked up from output devices						X	X
9.3	All sensitive hard copy output is secured and locked						X	X
	10.0 Marking							
10.1	Sensitive data is marked with the appropriate security label						X	X

NR.	ITEM	Y	\mathbf{N}	N/A	FINDING*	RECOMMENDATIONS	DISA/NIST MINIMUM SECURITY STANDARD FOR RESTRICTED AREAS	BEST PRACTICE
	11.0 Incident							
	Response							
11.1	Incident Response						X	X
	Plan/Procedure							
11.2	Computer						X	X
	Emergency Response							
	Team (CERT)							